



**BILL OF MATERIALS**

MARK	DESCRIPTION	LENGTH	NUMBER REQUIRED	MATERIAL
A1	TOP CHORD	L 1-1/2x1-1/2x 1/8	11'-7 3/4"	1 A36
A2	BOTTOM CHORD	L 1-1/2x1-1/2x 1/8	11' 2"	1 A36
A3	BASE	L 1-1/2x1-1/2x 1/8	0'-5-1/2"	1 A36
A4	VERTICAL END	L 1-1/2x1-1/2x 1/8	1'- 5 1/4"	2 A36
W1	WEB	L 1-1/4x1-1/4x1/8	1'-5 1/4"	1 A36
W2	WEB	L 1-1/4x1-1/4x1/8	1' 7"	10 A36

**NOTES:**

1. PURLINS TO BE MINIMUM #2 SYP 2x6 SPACED AT 2'-0" O.C.
2. INCREASE IN ALLOWABLE STRESS FOR WIND LOADING HAS BEEN USED.
3. TRUSS WEB MEMBER CONFIGURATION MAY VARY. ADJUST MEMBER LENGTHS ACCORDINGLY. MAXIMUM PANEL DISTANCE = 2'-0".
4. THIS TRUSS DESIGN MAY BE USED FOR SHORTER SPANS, ADJUST MEMBER LENGTHS ACCORDINGLY.
5. THIS TRUSS DESIGN MAY BE USED FOR ALL ROOF SLOPES UP TO 5:12, ADJUST MEMBER LENGTHS ACCORDINGLY.
6. CONTRACTOR RESPONSIBLE FOR TEMPORARY CONSTRUCTION & PERMANENT BRACING.
7. FABRICATION AND WELDING PER AISC AND AWS.
8. DESIGN IS FOR TRUSS ONLY.
9. FABRICATOR SHALL VERIFY DIMENSIONS BEFORE FABRICATING TRUSS.

**DESIGN LOADS**

(APPLIED PER INTERNATIONAL BUILDING CODE (IBC) 2009 UNLESS NOTED)

WIND SPEED = 90 MPH (IBC - 2009 AND ASCE 7-05)

WIND SPEED = 105 MPH (IBC - 2012 or 2015 AND ASCE 7-10)

GROUND SNOW LOAD = 10 PSF

12' TRUSS SPACING = DEAD LOAD = 4 PSF    ROOF LIVE LOAD = 20.0 PSF  
 10' TRUSS SPACING = DEAD LOAD = 8 PSF    ROOF LIVE LOAD = 20.0 PSF  
 8' TRUSS SPACING = DEAD LOAD = 12 PSF    ROOF LIVE LOAD = 20.0 PSF

THIS DRAWING WAS PRODUCED BY JOHN D. HYDE AND MAY NOT BE MODIFIED IN ANY WAY NOR SHALL THIS DRAWING BE USED BY ANYONE OTHER THAN AGCOR STEEL, LLC. OR ITS ASSIGNS WITHOUT THE EXPRESS WRITTEN PERMISSION OF JOHN D. HYDE WHOSE PROFESSIONAL ENGINEER'S STAMP APPEARS ON THIS DRAWING.



BY:  
 JOHN D. HYDE, PE  
 AL REG NO 11859  
 177 ARLINGTON ROAD  
 ARAB, AL 35016  
 PH 256-572-0195  
 jdhyde@mindspring.com

SCALE AS NOTED	DATE 08-3-2017	DRAWN BY J. HYDE	DRAWN NO. 17-0803-14LT
12'-0" ROOF TRUSS			SHEET NO. 1 OF 1